



先進核能安全分析技術之建立與應用

報告人：王仲容

106.09.11



大綱

- 簡介
- 安全分析技術之建立與應用
- 結論
- 動畫展示




簡介

- 核能安全分析技術可幫助及提升核電廠之安全。
- 參與CAMP、CSARP、RAMP、DECOVALEX國際合作計畫，建立與世界各國學術團體的研究合作管道，引進相關程式。
- 使用這些程式，發展與精進核能安全分析技術，投入相關研究與應用。



- LAPUR (Oak Ridge National Laboratory)
- TRACE (U.S. NRC)
- RELAP5 (U.S. NRC)
- PARCS (University of Michigan)
- FRAPCON/FRAPTRAN (Pacific Northwest National Laboratory)
- DAKOTA (Sandia National Laboratories)
- MELCOR (Sandia National Laboratories)
- PCTRAN (Micro-Simulation Technology)
- EPZDose
- CFD
- SAPHIRE (U.S. NRC)
- SCALE (Nuclear Energy Agency)
- TOUGH2 (Lawrence Berkeley National Laboratory)
- ALOHA (National Oceanic and Atmospheric Administration (NOAA))
- RESRAD(U.S. NRC)
- RAMP Codes



RAMP Codes

反應器氣體及液體放射性物質排放評估 (GALE)

生物圈之輻射劑量及風險評估 (GENII)

皮膚污染劑量評估 (VARSKIN)

放射性核種遷移、移除與劑量評估 (RADTRAD)

電廠人員與民眾的即時劑量評估 (Radiological Toolbox)

電廠除役後場址內殘留輻射評估 (DandD)

電廠與相關設備輻射外洩後果評估 (RASCAL)

人體器官輻射劑量估算工具 (PIMAL)

控制室適居性評估程式HABIT之介紹與應用


- **SAPHIRE** 風險評估分析模式
- **SCALE** 再臨界分析模式
- **CFD** 於核能安全之相關應用
- **ALOHA** 毒性化學物質之濃度評估
- **RESRAD** 除役之相關應用

DECOVALEX

- **TOUGH2** 於高放射性廢棄物最終處置之相關應用




安全分析技術之建立與應用





Prev. page





- 美國核管會 (U.S. NRC) 正在發展一套全新且先進的核電廠熱水流安全分析程式TRACE，並成立一國際合作計畫「CAMP」致力改良與發展TRACE程式
- 同時亦另發展一圖形化介面程式SNAP，來處理TRACE的相關計算及動畫展示
- 本研究室已參與此項國際合作計畫，積極投入人力參與

TRACE的相關研究

Nuclear Engineering & Science, NTHU

國立清華大學核子工程與科學研究所




NUREG/IA's published (2009-2017) Total of 116


- Spain – 26
- Slovenia – 13
- Finland – 6
- Germany – 9
- Korea – 7
- Czech Republic – 6
- Republic of China – 27
- Sweden – 5
- Argentina – 1
- Canada – 4
- Italy - 3
- People's Republic of China -2
- Poland - 4
- United Kingdom – 1
- Switzerland – 2
- Croatia – 1
- Ukraine - 1






核二廠TRACE model(含圍阻體)







核一廠用過燃料池TRACE model





核二廠乾式貯存系統TRACE model








- The Ultimate Response Guideline Simulation and Analysis Using **TRACE**, MAAP5, and FRAPTRAN for the Chinshan Nuclear Power Plant, *Annals of Nuclear Energy*, Vol. 103, pp. 402-411, 2017.
- **TRACE**/FRAPTRAN Analysis of Kuosheng Nuclear Power Plant Dry-Storage System, *International Journal of Chemical, Molecular, Nuclear, Materials and Metallurgical Engineering* Vol:8, No:7, 2014.
- The Study of Ultimate Response Guideline of Kuosheng BWR/6 Nuclear Power Plant Using **TRACE** and SNAP, *World Academy of Science, Engineering and Technology*, *International Journal of Chemical, Molecular, Nuclear, Materials and Metallurgical Engineering* Vol:11, No:4, 2017.
- Analysis of A Postulated ELAP Event in Maanshan NPP Using **TRACE** Code, *TopSafe2017*, 12 - 16 February 2017 in Vienna, Austria.



Kuosheng NPP SBO with LOCA

Time 200s

Sequence of Events (sec)




Reactor building




Initial condition

Power(MW)	2.96395341E9	Steam flow (kg/sec)	1661.7587
Dome pressure(MPa)	7.177173	Feedwater flow (kg/sec)	1661.6349
Core inlet flow (kg/sec)	10630.269	Max. fuel temperature(K)	566.9407
Vessel water level(m)	13.609825	RCIC flow (kg/s)	0.0



Containment information

Suppression pool	Vent annulus
Pressure 101499.48 Pa	Pressure 106683.836 Pa
Liquid temp 308.28058 K	Liquid temp 308.2975 K
Gas temp 308.68082 K	Gas temp 327.03918 K
Drywell	Reactor building
Pressure 106788.33 Pa	Pressure 100972.06 Pa
Liquid temp 337.98746 K	Liquid temp 308.22867 K
Gas temp 335.87878 K	Gas temp 308.27975 K







Kuosheng NPP SBO with LOCA

Time 2523s

Sequence of Events (sec)

Reactor warm	200.2s
Steam line break	200.2s
Loss of FW	200.2s
RP trip	200.2s
MSV close	200.2s
water level to L3	202s
water level to L2	209s
water level to TAF	217s
Fuel temp > 1000K	109s
Fuel temp > 1470K	249s




Initial condition

Power(MWt)	4.2723624E7	Steam flow (kg/sec)	3.4685261
Dome pressure(MPa)	0.14741652	Feedwater flow (kg/sec)	0.0
Core inlet flow (kg/sec)	55.621582	Max. fuel temperature(K)	1507.0305
Vessel water level(m)	5.351965	RCIC flow (kg/s)	0.0


Power (W)




Vessel water level (m)



Max. Fuel Temp (K)



Frac of Zr reacted (%)



Containment information

Suppression pool	Vent annulus
Pressure 126768.71 Pa	Pressure 146942.48 Pa
Liquid temp 330.4606 K	Liquid temp 331.16302 K
Gas temp 329.33325 K	Gas temp 416.3433 K
Drywell	Reactor building
Pressure 146830.52 Pa	Pressure 126135.04 Pa
Liquid temp 383.8597 K	Liquid temp 314.1887 K
Gas temp 652.36896 K	Gas temp 323.42477 K








Kuosheng drystorage fully cover

5 10 15 20 25 day


Temperature (K)




Cladding Hoop Strain



Cladding Hoop Stress (MPa)



Oxide Thickness (mm)



Safety criteria of temperature



Component	Normal storage	Accident	Full Cover
Fuel cladding	673K	843K	523.982 K
Steel canister	700K	700K	463.035 K
Concrete-shielded	366.6K	499.9K	300.0 K



Kuosheng drystorage fully cover

5 10 15 20 25 day


Temperature (K)




Cladding Hoop Strain



Cladding Hoop Stress (MPa)



Oxide Thickness (mm)





Safety criteria of temperature

Component	Normal storage	Accident	Full Cover
Fuel cladding	673K	843K	783.1177 K
Steel canister	700K	700K	727.994 K
Concrete-shielded	366.6K	499.9K	693.2012 K



Kuosheng drystorage fully cover 5 10 15 20 25 day

Temperature (K)




Safety criteria of temperature			
Component	Normal storage	Accident	Full Cover
Fuel cladding	673K	843K	1006.78046 K
Steel canister	700K	700K	954.85315 K
Concrete-shielded	366.6K	499.9K	845.1142 K


Cladding Hoop Strain



Cladding Hoop Stress (MPa)



Oxide Thickness (mm)






- 在FRAPCON/FRAPTRAN分析方面，可結合TRACE的分析結果，
進行在特定暫態下之燃料棒性質分析
- FRAPCON/FRAPTRAN分析結果可得到相關之燃料棒參數如：
護套溫度、燃料丸溫度、應力或應變等機械性質



FRAPTRAN fuel rod model







- The Analysis of Kuosheng Nuclear Power Plant Spent Fuel Pool by Using **FRAPTRAN-2.0**, ICAPP 2017, April 24-28, 2017 / FUKUI and KYOTO, JAPAN.
- Application of TRACE and **FRAPTRAN** in the Spent Fuel Pool of Chinshan Nuclear Power Plant, Applied Mechanics and Materials, Vols. 479-480, pp. 543-547, 2014.
- The Analysis of TRACE/**FRAPTRAN** in the Fuel Rods of Maanshan PWR for LBLOCA, World Academy of Science, Engineering and Technology, Vol. 85, pp. 52-57, 2014.
- Fuel Rod Behavior and Uncertainty Analysis by **FRAPTRAN**/TRACE/DAKOTA Code in Maanshan LBLOCA, NUREG/IA-0471, 2016.



- 國際合作計畫「CSARP」致力改良與發展MELCOR程式
- 圖形化介面程式SNAP可處理MELCOR的相關計算及動畫
展示
- 本研究室已參與此項國際合作計畫，積極投入人力參與MELCOR的相關研究




核一廠MELCOR model(含圍阻體)




Pressure settings of failure path
Drywell to reactor building 3F
5 Atm
Reactor building 5F to environment
1.5 Atm



核一廠用過燃料池MELCOR model



CVH component



Core Cell Data

Top Down View

Side View

Axial Levels	Ring 1	Ring 2	Ring 3	Ring 4
Level: 10	110	210	310	410
Level: 9	109	209	309	409
Level: 8	108	208	308	408
Level: 7	107	207	307	407
Level: 6	106	206	306	406
Level: 5	105	205	305	405
Level: 4	104	204	304	404
Level: 3	103	203	303	403
Level: 2	102	202	302	402
Level: 1	101	201	301	401

General

Active Cell: True False

Reference Cell: R 0 Z 0


Adjacent Volume: <Different Values>

Bypass Volume: <Different Values>

Particulate Debris: Valid values

Bypass Debris: Valid values

Concomitant Debris: <Different Values>






MELCOR 2.1 Chinshan NPP Spent Fuel Pool 0.0s


Sequence of events (hour)



Fuel temperature (K)




ZrO₂ (kg)




Pool water level (m)



Fuel temperature (K)








Cumulative hydrogen (kg)





MELCOR 2.1 Chinshan NPP Spent Fuel Pool 201500.0s










MELCOR 2.1 Chinshan NPP Spent Fuel Pool 355500.0s

Sequence of events (hour)

TAF	57
>1088K	91
>1477K	92






- The Model Establishment and Analysis of TRACE/**MELCOR** for Kuosheng Nuclear Power Plant Spent Fuel Pool, *International Journal of Chemical, Molecular, Nuclear, Materials and Metallurgical Engineering* Vol:10, No:10, 2016.
- The Mitigation Strategy Analysis of Kuosheng Nuclear Power Plant Spent Fuel Pool Using **MELCOR2.1**/SNAP, *International Journal of Chemical, Molecular, Nuclear, Materials and Metallurgical Engineering* Vol:11, No:4, 2017.
- Uncertainty Analysis for Chinshan (BWR/4) Spent Fuel Pool Severe Accident By **MELCOR2.1**/SNAP and DAKOTA, in *2015 Top Fuel*. 2015:Zurich.
- **MELCOR** Analysis on Hydrogen Behaviors of Chinshan NPP Spent Fuel Pool, in *PSAM-13*. 2016: Korea.




- 本研究室於2016年開始加入RAMP國際合作計畫，積極投入相關人力，使用RAMP的相關程式，進行核能電廠之輻射劑量評估、除役、大氣擴散因子等方面的相關研究
- RAMP相關的程式如下：
RADTRAD、HABIT、RASCAL、DAND、GENII、GALE、PIMAL
、VARSKIN、ARCON、PAVEN等。



- RADTRAD (RADionuclide, Transport, Removal And Dose Estimation Computer Code, 放射性物質遷移、移除及劑量評估簡算程式)是由美國聖地亞國家實驗室(Sandia National Laboratory, SNL)所研發，可進行放射性物質遷移、移除及劑量評估之計算，主要用於評估廠界劑量，包括EAB、LPZ，以及核電廠內控制室的職業輻射曝露。
- 圖形化介面程式SNAP可處理RADTRAD的相關計算








核三廠RADTRAD model

source term: 100 % noble gas, 25 % iodine





- HABIT程式為U. S. NRC所發展的控制室適居性評估程式，此程式假設核電廠發生事故，造成化學物質(氣態或液態)釋放時，評估其對於控制室適居性之影響
- HABIT程式目前最新的版本為2.0，並持續進行更新中，根據其簡報資料，未來將移除radionuclides的分析，只保留化學物質的分析



HABIT - Computer Codes for Evaluation of Control Room Habitability

Design Help

Main | **EXTRAN** | CHEM | Output Log

Design Title This is a blank design to get started.

Model

Radionuclides

Use same data for filtered paths 1 and 2

```

graph TD
    A["A FPPF_2 (1)"] -- Unfilt 1 --> CONHAB["CONHAB"]
    B["B FPPF_2 (2)"] -- Unfilt 2 --> CONHAB
    C["TACT5 (1)"] -- Filt 1 --> CONHAB
    D["TACT5 (2)"] -- Filt 2 (recirc) --> CONHAB
          
```

Chemicals

```

graph TD
    E["EXTRAN"] --> F["CHEM"]
          
```

Included Codes

Chemicals

EXTRAN

CHEM

Radionuclides

FPPF_2 (1)

FPPF_2 (2)

TACT5 (1)

TACT5 (2)

CONHAB

Dispersion

DEGADIS

SLAB

Only Show Codes Included

Key

Code Included in Design	Code Not Included in Design	Code Computations Ran in Session
-------------------------	-----------------------------	----------------------------------

Nuclide Database : C:\Users\user\Documents\HABIT\Data\NuclideDatabases\MLWR_TID.30

NEW ...



ALOHA程式之化學毒物擴散計算

- ALOHA程式為美國用於工業界的化學物質擴散事故之分析程式，NRC正在嘗試HABIT與ALOHA程式之驗證及比較，用以強化控制室適居性之安全分析。
- 目前ALOHA已有初步分析結果用以比對HABIT分析。



ALOHA可模擬不同貯存方式之化學物質事故，包含洩漏或爆炸

Tank Size and Orientation

Select tank type and orientation:

Horizontal cylinder

Vertical cylinder

Sphere

Enter one of two values:

diameter feet meters

volume liters cu meters



Atmospheric Options

Wind Speed is : knots mph meters/sec

Wind is from : Enter degrees true or text (e.g. ESE)

Measurement Height above ground is:

OR enter value : feet meters

Ground Roughness is :

Open Country Urban or Forest OR Input Roughness [Zo] :

Open Water

Select Cloud Cover :

OR enter value :

complete cover partly cloudy clear

圖為ALOHA程式各種氣象條件之輸入，相對於HABIT又更加詳盡

Atmospheric Options 2

Air Temperature is : Degrees F C

Stability Class is : A B C D E F

Inversion Height Options are :

No Inversion Inversion Present, Height is : feet meters


Select Humidity :

OR enter value : %


wet medium dry



ALOHA可結合程式MARPLOT輸出世界各地之地圖，圖為核三廠



ALOHA分析核三廠二氧化碳槽爆炸事故之戶外濃度結果



grams/(cu m)



— Outdoor Concentration

— Indoor Concentration

At Point: West: 504 yards North: 243 yards




- Using **RADTRAD** and SNAP to Establish the Analysis Model for Maahshan PWR Plant , World Academy of Science, Engineering and Technology International Journal of Nuclear and Quantum Engineering Vol:4, No:7, 2017.
- Using **HABIT** to Establish the Chemicals Analysis Methodology for Maanshan Nuclear Power Plant, World Academy of Science, Engineering and Technology, International Journal of Chemical, Molecular, Nuclear, Materials and Metallurgical Engineering Vol:11, No:6, 2017.
- The Establishment of the Analysis Methodology for Maanshan Nuclear Power Plant Using **RADTRAD, HABIT, and ALOHA**, KERNTTECHNIK 2017.(已投稿)



RASCAL程式



RASCAL可計算用過燃料池及乾式貯存設施事故下之放射產物釋出結果





環境輻射劑量評估

GALE程式

- ALE中文名稱為輕水式核電廠氣液態排放物輻射估算程式 (Gaseous And Liquid Effluent from commercial light water nuclear power plants)，其主要使用FORTRAN程式語言編寫，用來計算核能電廠(包含PWR及BWR)所排出氣體及液體放射性物質的活性含量。
- 其根據電廠模式可分為BWR-GALE與PWR-GALE兩種
- 可下載程式版本有兩種
 - GALE86
 - GALE-2.0 BETA (最新版本)
- 參考文件
 - [NUREG-0016 Revision 1, Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Boiling Water Reactors \(BWR-GALE Code\)](#)
 - [NUREG-0017 Revision 1, Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Pressurized Water Reactors \(PWR-GALE Code\)](#)



GALE BWR主畫面

BWR GALE-2.0



建立新檔名或使用舊存檔

Input File Name:

Type of Analysis:

Gas

Liquid 分析模式選擇

Output Files:

Gas:

Liquid: 輸出檔名

Legacy Input 輸入舊格式檔案

Read Legacy Input

Gas Input:

Gas Output:

Liquid Input:

Liquid Output:



GALE2.0 Output file

maanshan_MUR PWR

GASEOUS RELEASE RATE - CURIES PER YEAR

	PRIMARY COOLANT (MICROCI/GM)	SECONDARY COOLANT (MICROCI/GM)	GAS STRIPPING		BUILDING VENTILATION			BLOWDOWN VENT OFFGAS	AIR EJECTOR EXHAUST	TOTAL
			SHUTDOWN	CONTINUOUS	REACTOR	AUXILIARY	TURBINE			
KR-85M	1.855E-02	4.806E-09	0.0E+00	0.0E+00	1.4E+01	0.0E+00	0.0E+00	0.0E+00	0.0E+00	1.4E+01
KR-85	1.657E-01	4.181E-08	6.0E+01	6.5E+02	3.0E+02	4.0E+00	0.0E+00	0.0E+00	2.0E+00	1.0E+03
KR-87	1.987E-02	1.425E-08	0.0E+00	0.0E+00	6.0E+00	0.0E+00	0.0E+00	0.0E+00	0.0E+00	6.0E+00
KR-88	2.095E-02	5.394E-09	0.0E+00	0.0E+00	1.2E+01	0.0E+00	0.0E+00	0.0E+00	0.0E+00	1.2E+01
XE-131M	5.509E-01	1.381E-07	1.4E+01	1.6E+02	9.7E+02	1.3E+01	0.0E+00	0.0E+00	6.0E+00	1.2E+03
XE-133M	7.229E-02	1.889E-08	0.0E+00	0.0E+00	1.2E+02	2.0E+00	0.0E+00	0.0E+00	0.0E+00	1.2E+02
XE-133	2.634E-02	6.647E-09	0.0E+00	0.0E+00	4.5E+01	0.0E+00	0.0E+00	0.0E+00	0.0E+00	4.5E+01
XE-135M	1.524E-01	3.859E-08	0.0E+00	0.0E+00	1.1E+01	4.0E+00	0.0E+00	0.0E+00	2.0E+00	1.7E+01
XE-135	7.671E-02	1.955E-08	0.0E+00	0.0E+00	8.2E+01	2.0E+00	0.0E+00	0.0E+00	0.0E+00	8.4E+01
XE-137	3.987E-02	1.015E-08	0.0E+00	0.0E+00	0.0E+00	0.0E+00	0.0E+00	0.0E+00	0.0E+00	0.0E+00
XE-138	7.149E-02	1.858E-08	0.0E+00	0.0E+00	5.0E+00	2.0E+00	0.0E+00	0.0E+00	0.0E+00	7.0E+00
TOTAL NOBLE GASES										2.5E+03

0.0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS THAN 1.0 CI/YR FOR NOBLE GAS, 0.0001 CI/YR FOR I




DandD電廠除役廠址劑量評估

- According to 10CFR part 20, the dose should lower than 0.25mSv/yr for releasing.
- DandD is the code which can simplify the regularity process of U.S.NRC.
- Reference:
NUREG-1549
NUREG/CR-5512



Status of RAMP codes in NTHU-DandD

Pathway-building occupancy



Status of RAMP codes in NTHU-DandD

Pathway-residential





Status of RAMP codes in NTHU-DandD

Building Nuclide Parameters

The screenshot displays the DandD software interface with several windows open. A central text box labeled "Radionuclides setting" points to the configuration for radionuclides 60Co and 137Cs.

Building Nuclide Parameters Window:

Nuclide Symbol	Area	Distribution Name	Input Units
60Co	UNLIMITED	CONSTANT	dpm/100 cm ²
90Sr	UNLIMITED	CONSTANT	dpm/100 cm ²
137Cs	UNLIMITED	CONSTANT	dpm/100 cm ²

Building Scenario 60Co Window:

- Distribution: CONSTANT
- Units of Measurement: dpm/100 cm²
- Value: 3

Residential Parameters Window:

Symbol	Name	Default	Read Only	Distribution Name	Input Units	Absolute Lower Bound	Absolute Upper Bound
Nunsat	Number of Unsaturated			CONSTANT	none	1.00E+00	5.00E+01
TstartR	Start Time			CONSTANT	days	1.00E+00	3.65E+01
TendR	End Time			CONSTANT	days	1.00E+00	3.65E+01
dR	Time Step Size			CONSTANT	days	1.00E+00	3.65E+01
PstepR	Print Step Size			CONSTANT	none	0.00E+00	3.65E+01
TI	Indoor Exposure Period			CONSTANT	days/year	0.00E+00	3.65E+01
TX	Outdoor Exposure Period			CONSTANT	days/year	0.00E+00	3.65E+01

Building Scenario 137Cs Window:

- Distribution: CONSTANT
- Units of Measurement: dpm/100 cm²
- Value: 1.2
- Area of Contamination: Contained in Limited Area, Area: 20 m²



Status of RAMP codes in NTHU-DandD

Case calculations:



- A decommission NPP with Co-60, Sr-90, Cs-137 for Residential
- 7 path included: External, Inhalation, Secondary ingestion, Agricultural, Drinking water, Irrigation, Surface water

Nuclide	Concentration (pCi/g)	Area of contamination (m ²)	Distribution
Co-60	1	40	Constant
Sr-90	1.5	30	Constant
Cs-137	2	20	Constant



Status of RAMP codes in NTHU-DandD

Results



TEDE was 11.3mRem, it's lower than the 10CFR part 20(25mRem).

DandD可以有效評估除役後場址的輻射劑量，用於後續除役過程之規劃



GENII


- 生物圈之輻射劑量及風險評估程式(GENII)為美國 Pacific Northwest National Laboratory(PNNL)所發展之分析軟體，該軟體可模擬當放射性核種外釋時，其傳播途徑可能造成的輻射劑量，可計算之傳播途徑包括地表水、大氣擴散、生物累積(動植物、水中生物)等，並評估當人類經由曝露、吸入與攝入等途徑接觸到放射性核種，對其造成的健康危害與風險，且 ICRP-20、ICRP-26、ICRP-30、ICRP-60等資料亦已納入程式模擬選項，可根據法規要求進行體內劑量的保守評估。GENII曾應用於美國Hanford場址復原及 Yucca Mountain計畫之環境輻射劑量評估。



GENII之操作介面，囊括多項環境及生物劑量評估的子程式

Framework for Risk Analysis in Multimedia Environmental Systems

File Site Customize GO... Help





About RESRAD



RESRAD-ONSITE for Windows

Version: 7.2

Created: July 20, 2016



The RESRAD-ONSITE computer code was developed under the joint sponsorship of the U.S. Department of Energy and the U.S. Nuclear Regulatory Commission for site-specific dose assessment of residual radioactivity.

Developed at the Environmental Science Division of Argonne National Laboratory.

[Email: resrad@anl.gov](mailto:resrad@anl.gov)

www.evs.anl.gov/resrad

Memory In Use: 47%



RESRAD-ONSITE 7.2 (7/20/16)

- Improved ICRP-107 radionuclide decay chain threads condensing routine to reduce computation time.
- Provided options to choose between the ICRP-38 radionuclide decay database and the ICRP107 radionuclide decay database.
 - Support to use either ICRP-26/30 or ICRP-60/72 based dose coefficients with the first option.
 - Support to use ICRP60 based dose coefficients from DCFPAK 3.02 with the second option.

RESRAD 7.0 (4/4/14)

- Extend DCF Database and software capability for ICRP 107; added Reference Person DCF's as an option
- Use of different cover and depth factors for photosynthesis and root uptake for C-14
- Updated Help for RESRAD and for DCF Editor
- Fix problem in graphics with multiply threaded progeny

RESRAD 6.5 (10/30/09)

- C-14 gaseous and particulate contributions to dose and risk available
- Partially or fully submerged contaminated zone now treated
- Choice between ICRP60 or FGR12 for External dose factors added
- 64-bit and Vista computers now supported

RESRAD 6.4 (12/20/07)

- Added ICRP 72 age-dependent DCFs
- Improved data storage and retrieval, user specified directories.
- User specified ground DCF's now possible.
- C-14 inhalation dose and risk improved.

RESRAD 6.3 (8/25/05)

- Added ICRP-38 radionuclides
- Allow variable half-life cutoff
- DCF Editor is now common between RESRAD and RESRAD-BUILD

EPZDose

Simulation Setup

Source Term

Source : Source Type

Release Height : m

Map

Name : MapName

Latitude : Latitude

Longitude : Longitude

Monitor Point : none

Meteorology

Wind Velocity(m/s) :

Wind From : N

Fallout fraction(%/h) :

Pasquill Conditions : F-Moderately stable

Save

Map Size : Auto Manual min

Transient Time : min

Plotting Time Step : 2 min

Dose Rates

Whole body

Thyroid

TEDE

Accumulated Doses

Whole body

Thyroid

TEDE

Show Monitor

Map

Mountain Park 獅頭山公園

金山

District 區

社

萬里加

頂社

Yuanlan Rd

清水坑

員潭子

八斗坑內

七甲尾

Yuanlan Rd

國聖埔

Yuanlan Rd

五拉路

太平洋新翠灣景日

Jade Golf & Country Club 翡翠高爾夫球場

Google

Map data ©2016 Google

Narrow Wide

Dose Rates(mSv/h)

Accumulated Doses(mSv)

0.001 0.01 0.1 1 10 100



- Developments and Applications of **EPZ Dose** for Offsite Dose Evaluations in Nuclear Power Plant Accident Conditions, Int. Top. Mtg. on Nuclear Thermal-Hydraulics, Operation and Safety (NUTHOS-9), Kaoshiung, Taiwan, Sept. 9-13, 2012.
- **EPZDose**, An offsite dose evaluation code for radioactive material release accidents,” PBNC, Vancouver, Canada, Aug. 24 – 28, 2014.
- Modeling Fukushima Dose Consequences with **EPZDose**, PBNC, Beijing, China, April 5-9, 2016.



EARTH &
ENVIRONMENTAL
SCIENCES



[OUR PEOPLE](#)

[RESEARCH](#)

[DEPARTMENTS](#)

[ABOUT](#)

[NEWS & EVENTS](#)

[SEARCH](#)

Nuclear Energy and Waste

Active

DECOVALEX



DOE-NE-NUCLEAR ENERGY

[Energy Resources](#)

PROGRAM DOMAIN

[View Project Website](#)

Project Contacts



Jens Birkholzer
Energy Geosciences
Division Director
Senior Scientist

DEvelopment of COupled Models and their VALidation Against EXperiments in Nuclear Waste Isolation

The DECOVALEX Project is a unique international research collaboration for advancing the understanding and mathematical modeling of coupled thermo-hydro-mechanical (THM) and thermo-hydro-chemical (THC) processes in geological systems. DECOVALEX is an acronym for "Development of Coupled Models and their Validation against Experiments." Starting in 1992, the project has made important progress and played a key role in the development of numerical modeling of coupled processes in fractured rocks and



Energy Geosciences Division Director, [Jens Birkholzer](#) was recently named the Chairman of the DECOVALEX Project, and LBNL is now serving as the coordinating organization for DECOVALEX. In addition, LBNL scientists have participated as modeling teams in various past DECOVALEX phases and several DECOVALEX projects. The current DECOVALEX Project phase (referred to as D-2019) started in Spring 2016 and will run through the end of 2019. Modeling tasks tackled in the current phase are:

- Task A: ENGINEER – Modeling advective gas flow through low permeability materials.
- Task B: Fault Slip Test – Modelling the induced slip of a fault in argillaceous rock.
- Task C: GREET – Hydro-mechanical-chemical-biological processes during groundwater recovery.
- Task D: INBEB – Hydro-mechanical interactions in bentonite engineered barriers.
- Task E: Upscaling Heater Tests – Upscaling of modelling and experimental results from small scale to one-to-one scale.
- Task F: FINITO – Fluid inclusion and movement in tight rock.
- Task G: EDZ Evolution – Reliability, feasibility and significance of Measurements of conductivity and transmissivity of the rock mass for the understanding of the evolution of a repository of spent nuclear fuel.




圖 3-1 熱傳、水力、力學與化學反應(THMC)之相互影響

- 將使用TOUGH2進行相關研究



結論

- 各項程式與分析技術皆可實際應用，相關之研究成果則可維護與提升國內核電廠之安全
- 將持續參與CAMP、CSARP、RAMP、DECOVALEX國際合作計畫，來引進新程式或更新程式版本
- 將持續發展與精進相關程式之模式與分析技術
- 將積極投入除役與高放之相關研究與應用



動畫展示



Thanks